

General Environmental Incident Summary

Incident: 3955 **Date/Time Notice:** 11/2/2015 1356 **DEM Incident No:**
Responsible Party: Plains Midstream
Date Incident: 11/2/2015 **Time Incident:** 1045 **Duration:** 5 minutes
County: McKenzie **Twp:** 151 **Rng:** 98 **Sec:** 35 **Qtr:**
Lat: 47.84880 **Long:** -103.17790 **Method:** Interpolation from map
Location Description: ONEOK Garden Creek Plant II, 3007 121st Ave NW Watford City, ND

Submitted By: Byron Skaley **Affiliation:** ONEOK Employee
Address: 2700 Lincoln Ave SE
City: Sidney **State:** MT **Zip:** 59270

Received By:

Contact Person: Jeff Schumack
325 McDonald Street North
Regina, SK S4N7M1

Distance Nearest Occupied Building: 1035 Feet **Release Contained:** Yes

Type of Incident: Valve on truck failed to open

Description of Released Contaminant: Condensate

Volume Spilled: 10.00 gallons

Ag Related: No

EPA Extremely Hazardous Substance: No

Reported to NRC: Unknown

Cause of Incident:

Dry lock valve on transport truck stuck closed pressuring system

Risk Evaluation:

No Immediate Risk

of Fatalities: 0

of Injuries: 0

Affected Medium: 03 - soil

Potential Environmental Impacts:

No Potential Environmental Impacts

Action Taken or Planned:

Soil was picked up and area cleaned

Wastes Disposal Location:

Agencies Involved:

Updates

Date: 11/4/2015 ***Status:*** Reviewed - No Action Required

Author: Souder, Taylor

Updated Volume:

Notes:

This release will be investigated in conjunction with a previous release.